

Certificate for external monitoring 2024

Index.-no. 28/2004/6

Monitored company:

asecos GmbH
Weiherfeldsiedlung 16-18
63584 Gründau
Germany

The above mentioned company is a manufacturer of safety cabinets according to DIN EN 14470-1 and DIN EN 14470-2. With regard to the fire resistance duration, a voluntary external monitoring was carried out as part of quality assurance in accordance with Monitoring Contract No. 28/2004/6.

By the monitoring laboratory

MPA Dresden GmbH
Fuchsmühlenweg 6F
09599 Freiberg
Germany

the manufacturing plant is subject to yearly monitoring and the manufactured cabinets are assessed for conformity with the classified type. Furthermore, the factory's own production control is examined with regard to the significant aspects for the fire behaviour of the safety cabinets.

Date of inspection:	2024-01-24
Date of Fire resistance test:	2024-02-15
taken cabinet model:	V90.196.081.VDAC


Factory production control and compliance with the classification of fire resistance according to DIN EN 14470-1 and DIN EN 14470-2 met requirements.

In case of doubt the German version of this certificate on external monitoring Index no. 28/2004/6 is valid.

Freiberg, 03 of June 2024


Dr.-Ing. A. Meißner
Manager Laboratory Fire Protection




M. Fischer, B. Sc.
Test Engineer Fire Protection