

Certificate on external monitoring

Index no. 28/2004/6

Monitored company:

asecos GmbH
Weiherfeldsiedlung 16-18
63584 Gründau
Germany

The above-mentioned company is a manufacturer of safety cabinets in accordance with DIN EN 14470 part 1 and part 2. In the scope of quality assurance, the external monitoring was conducted with respect to the fire resistance period, according to monitoring contract no. 28/2004/6.

Monitoring institute:

MPA Dresden GmbH
Fuchsmühlenweg 6F
09599 Freiberg
Germany

The cabinet Q90.195.120 from batch production was sampled under supervision and subjected to a fire resistance test in accordance with DIN EN 14470 part 1.

The monitoring institute will review the manufacturing plant annually, and the produced cabinets will be evaluated with regard to their conformity to the type classified in the initial test. Furthermore, the internal production control will be evaluated with regard to the aspects that are significant for the fire behaviour of the safety cabinets.

The certificate ceases to be valid on 31. December 2017.

In case of doubt the German version of test certificate on external monitoring index no. 28/2004/6 is valid.

Freiberg, 20. March 2017



Dr.-Ing. Meißner
Qualified Engineer
Manager of the field of fire prevention