

Certificate for external monitoring 2019

Index.-no. 28/2004/6

Monitored company:

asecos GmbH
Weiherfeldsiedlung 16-18
63584 Gründau
Deutschland

The above mentioned company is a manufacturer of safety cabinets according to DIN EN 14470-1 and DIN EN 14470-2. With regard to the fire resistance duration, a voluntary external monitoring was carried out as part of quality assurance in accordance with Monitoring Contract No. 28/2004/6.

By the monitoring laboratory

MPA Dresden GmbH
Fuchsmühlenweg 6F
09599 Freiberg
Deutschland

the manufacturing plant is subject to yearly monitoring and the manufactured cabinets are assessed for conformity with the classified type. Furthermore, the factory's own production control is examined with regard to the significant aspects for the fire behaviour of the safety cabinets.

Date of inspection: 24.01.2019
Date Fire resistance test: 28.03.2019
taken cabinet model: S90.196.060.WDAS

Factory production control and compliance with the classification of fire resistance according to DIN EN 14470-1 and DIN EN 14470-2 met the requirements.

In case of doubt the German version of this certificate on external monitoring Index no. 28/2004/6 is valid

Freiberg, 1st of April 2019



Dr.-Ing. A. Meißner
Laboratory Manager Fire Protection

MPA Dresden GmbH
Fuchsmühlenweg 6F
09599 Freiberg
www.mpa-dresden.de

Geschäftsführer: Thomas Hübler
Tel. +49(0)3731-20393-0
Fax +49(0)3731-20393110
E-Mail info@mpa-dresden.de

Amtsgericht Chemnitz HRB 28268
Steuernummer: 220/114/03364
USt-IdNr. DE291271296



J. Reich, M. Sc.
Test engineer fire protection

Sparkasse Mittelsachsen
Poststraße 1a
09599 Freiberg
IBAN DE68 870520003115024672
BIC WELADED1FGX